



PROGRAM LOCK PH: MUST PROGRAM HIGH/LOW OUTPUT FOR "ON REQUEST TO EXIT" TO HIGH. MUST PROGRAM HIGH/LOW OUTPUT FOR "ON DOOR OPEN" TO LOW. MUST PROGRAM HIGH/LOW OUTPUT FOR "ON TROUBLE" TO LOW.

UTC/CASI DIRECDOOR CONTROLLER SUPPORTS ONE OR TWO AD400 OFF A SINGLE PIM400-TD2. SINGLE DOOR SHOWN FOR CLARITY. WIRING SHOWN REFLECTS WIRING FROM CONTROLLER TO PIM400-TD2 ONLY. ADDITIONAL WIRING IS REQUIRED AND WILL NOT BE SHOWN HERE.

FOR REMOTE UNLOCKING BE SURE TO ENABLE WOR WITH HHID (THIS WILL CAUSE UNLOCK AND LOCKDOWN COMMANDS TO OCCUR WITHIN 10 SECONDS) . WHEN TESTING REMOTE UNLOCKS COVER MUST BE INSTALLED ON PIM400-TD2 OR PUT TAMPER IN MAINTENANCE MODE ("PULL TAMPER PLUNGER OUT") .

OPTIONALLY CAN USE EOL RESISTORS FOR SUPERVISED CONTACTS. POE. POWER OVER ETHERNET. IS NOT VERIFIED FOR UL INSTALLATIONS.

CREATOR: BRENDA DOVE 09/14/11	TITLE: UTC/CASI DIRECDOOR	914111UTC-CASI
APPROVED: ALEX SZABO	PIM400-TD2 X RLBD WITH AD400 LOCK	REV 2
		REV 2/11/12